



Microbac Laboratories, Inc., Newton

CERTIFICATE OF ANALYSIS

1HL0695

Hardeman R-10 School

Project Name: MO Schools Lead Testing

Carey Johnson
21051 Highway D
Marshall, MO 65340

Project / PO Number: N/A
Received: 12/10/2024
Reported: 12/19/2024

Analytical Testing Parameters

| | | | |
|--------------------------|----------------------|-------------------------|------------------|
| Client Sample ID: | North Faucet Kitchen | Collected By: | Johnson,Carey |
| Sample Matrix: | Drinking Water | Collection Date: | 12/04/2024 15:30 |
| Lab Sample ID: | 1HL0695-01 | | |

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|-------------------------------|--------|-----|-------|----|------|---------------|---------------|---------|
| 200.8 | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 12/17/24 0812 | 12/17/24 1822 | RVV |

| | | | |
|--------------------------|----------------------|-------------------------|------------------|
| Client Sample ID: | South Faucet Kitchen | Collected By: | Johnson,Carey |
| Sample Matrix: | Drinking Water | Collection Date: | 12/04/2024 15:30 |
| Lab Sample ID: | 1HL0695-02 | | |

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|-------------------------------|--------|-----|-------|----|------|---------------|---------------|---------|
| 200.8 | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 12/17/24 0812 | 12/17/24 1827 | RVV |

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Sue Thompson
Client Services Manager
suzanne.thompson@microbac.com
12/19/24 08:56